

2024년 8월 공공하수처리시설 하수처리현황

□ 수처리 현황

구분	용량	유입수							방류수							비고
		pH	BOD	TOC	SS	T-N	T-P	대장균	pH	BOD	TOC	SS	T-N	T-P	대장균	
법정수질	500이상									10.0	25(15)	10.0	20.0	0.5(0.3)		
	500~50									10.0	25.0	10.0	20.0	2.0		
	50이하									10.0	25.0	10.0	40.0	4.0		
합천	5,000	7.1	105.7	75.3	176.3	46.425	3.842	1,171,613	6.9	0.8	2.8	0.8	5.984	0.049	-	
초계·적중	1,400	7.1	85.0	50.3	118.1	27.152	2.528	1,475,323	6.8	1.0	2.0	0.9	4.108	0.053	77	
가야·야로	2,000	7.2	45.9	43.4	85.2	23.644	2.279	182,097	6.8	0.8	1.6	0.8	4.492	0.045	10	
삼가	900	7.9	124.1	64.6	130.3	40.006	3.530	1,109,806	7.6	0.8	2.8	0.8	3.045	0.060	3	
가호	660	7.3	95.5	57.7	99.2	24.860	2.351	1,591,452	7.0	0.9	2.6	1.2	5.800	0.054	-	
용주	50	7.3	68.1	70.6	97.0	41.213	3.252	629,500	7.0	0.8	3.2	0.7	12.467	1.166	-	
봉계	68	6.9	93.7	49.5	84.0	31.598	2.616	345,500	6.8	2.3	3.9	4.1	10.023	0.706	130	
두심	70	7.3	108.0	70.2	88.0	21.360	1.980	1,001,750	7.0	2.9	4.1	2.3	6.887	0.423	213	
구평	46	8.3	68.6	71.9	72.5	22.035	1.982	463,000	7.7	1.2	2.2	1.6	5.396	0.429	130	
봉산	150	6.9	108.8	67.5	122.0	49.688	3.834	348,250	6.8	3.0	2.8	1.8	8.613	1.029	77	
묘산	120	7.2	68.7	46.7	112.0	32.138	3.182	1,365,750	6.8	3.3	4.7	2.7	7.836	0.787	136	
대병	170	7.3	93.4	64.3	75.0	33.180	3.030	1,108,750	7.0	1.7	2.0	2.4	3.027	0.738	110	
회양	150	7.3	157.0	69.1	129.5	26.085	3.390	1,026,250	7.0	0.6	1.7	0.8	7.064	0.946	-	
해인사	300	7.3	49.3	42.4	76.0	20.685	2.385	81,500	6.6	5.5	5.0	5.6	10.785	1.118	238	
마장	50	7.1	41.7	35.3	74.0	24.795	2.303	73,250	6.8	6.2	3.7	4.9	7.298	0.488	427	
권빈	70	6.9	117.0	55.9	68.5	30.173	3.338	262,750	6.8	1.2	2.1	1.5	3.473	0.691	46	
가회	120	8.1	68.1	71.4	171.0	33.165	3.276	859,250	7.7	0.5	1.9	2.6	8.006	0.891	65	
쌍백	200	7.9	54.0	62.7	72.0	41.453	3.297	545,000	7.4	1.1	2.6	3.6	10.089	1.002	117	
계산	50	6.9	50.1	51.0	68.0	25.118	2.778	128,250	6.8	4.6	2.9	1.9	6.071	0.771	182	
유전	85	7.3	75.8	55.2	67.5	25.320	2.147	508,750	7.0	1.4	2.0	2.5	8.030	0.460	68	
청덕	115	7.2	52.0	47.9	62.5	29.685	3.110	2,277,500	6.9	1.7	2.4	2.4	7.256	1.409	-	
쌍책	165	7.1	175.5	71.5	86.5	28.500	2.696	1,985,000	6.9	1.4	2.6	4.3	6.371	0.990	183	
대양	180	6.9	56.7	54.8	65.5	34.418	3.077	269,000	6.8	2.0	4.6	2.1	12.875	1.338	221	
덕곡	75	7.2	94.4	75.1	124.0	50.228	4.190	1,277,500	6.9	1.5	5.4	2.1	9.576	1.168	229	
매안	110	7.1	124.9	78.4	114.0	42.660	3.618	1,480,000	6.6	3.5	4.6	6.2	12.300	0.798	174	
울곡	250	7.2	104.4	55.5	116.5	40.965	4.526	1,342,500	6.8	3.1	3.7	4.7	6.315	0.995	66	