

2024년 9월 공공하수처리시설 하수처리현황

□ 수처리 현황

구분	용량	유입수							방류수							비고
		pH	BOD	TOC	SS	T-N	T-P	대장균	pH	BOD	TOC	SS	T-N	T-P	대장균	
법정수질	500이상									10.0	25(15)	10.0	20.0	0.5(0.3)		
	500~50									10.0	25.0	10.0	20.0	2.0		
	50이하									10.0	25.0	10.0	40.0	4.0		
합천	5,000	7.1	107.8	70.1	153.5	47.180	3.903	1,168,167	6.9	0.7	2.2	0.9	6.399	0.045	-	
초계·적중	1,400	7.1	90.6	49.5	115.0	30.550	2.717	1,722,000	6.8	1.1	2.0	1.1	4.451	0.045	58	
가야·야로	2,000	7.2	66.4	41.0	85.0	26.313	2.450	222,500	6.9	1.0	1.3	0.7	4.857	0.042	9	
삼가	900	7.9	96.7	60.1	103.7	40.699	3.680	1,227,500	7.5	0.9	2.5	0.8	3.545	0.053	18	
가호	660	7.3	93.3	59.1	112.1	29.914	2.619	2,025,500	7.0	1.1	1.8	1.0	5.775	0.045	-	
용주	50	7.3	49.3	64.9	101.5	27.315	2.543	911,500	7.0	0.7	2.8	0.7	8.738	0.634	-	
봉계	68	6.9	70.0	40.8	56.0	25.028	2.094	474,500	6.8	2.4	5.2	3.6	7.259	0.430	178	
두심	70	7.1	111.5	75.4	139.5	21.855	2.061	433,750	6.9	2.6	3.1	2.9	5.370	0.492	142	
구평	46	8.0	69.8	53.5	115.0	20.805	2.001	792,500	7.6	1.1	2.7	2.5	5.066	0.400	159	
봉산	150	6.9	172.9	51.2	87.0	41.895	4.691	332,250	6.8	2.2	2.7	3.7	8.270	0.757	39	
묘산	120	7.3	75.0	53.6	108.0	29.055	2.688	455,250	6.9	2.9	3.6	2.3	6.702	0.409	37	
대병	170	7.2	46.9	54.7	108.5	30.893	2.901	748,750	6.9	1.3	2.0	4.2	6.489	0.451	18	
회양	150	7.3	149.4	53.2	106.5	27.855	2.189	1,497,500	7.0	0.6	2.0	2.7	6.321	0.397	-	
해인사	300	7.1	31.6	45.0	107.0	24.368	2.106	141,750	6.7	3.8	4.8	7.1	9.240	0.657	132	
마장	50	7.3	31.0	52.3	98.0	25.695	2.324	90,250	6.9	4.2	1.7	4.7	6.770	0.336	66	
권빈	70	6.9	99.6	54.7	71.5	26.055	2.517	629,500	6.8	1.2	3.2	1.8	3.329	0.613	96	
가회	120	7.8	70.5	58.4	126.5	34.208	3.290	816,250	7.6	0.7	2.1	3.1	7.128	0.555	31	
쌍백	200	8.2	73.1	54.3	109.0	38.048	3.239	667,750	7.7	1.1	3.7	2.6	6.140	0.691	136	
계산	50	6.9	116.4	57.7	101.0	30.578	3.317	374,000	6.8	3.0	3.2	2.7	5.891	0.528	134	
유전	85	7.3	44.9	56.1	84.0	30.450	3.119	1,597,500	7.0	0.7	3.1	3.5	4.865	0.606	78	
청덕	115	7.1	131.6	63.0	116.0	32.655	3.102	1,632,500	6.8	2.3	2.6	4.9	7.257	0.538	-	
쌍책	165	7.2	157.2	49.6	111.0	34.020	3.680	1,647,500	6.9	0.9	1.6	5.6	5.909	0.512	131	
대양	180	6.9	63.6	83.7	98.5	38.348	3.315	1,293,250	6.8	2.8	3.0	3.0	7.478	0.489	213	
덕곡	75	7.1	71.5	59.3	103.0	47.580	4.397	1,060,000	6.8	1.6	4.5	2.5	8.496	0.624	68	
매안	110	7.2	119.7	61.3	120.5	32.625	2.922	1,255,000	6.8	1.9	3.3	5.5	7.002	0.302	191	
울곡	250	7.2	76.4	48.0	93.0	46.515	4.163	1,925,000	6.8	5.8	2.8	6.1	7.592	0.632	147	